



OFFICE OF THE DISTRICT FIRE OFFICER
KARNATAKA FIRE & EMERGENCY SERVICES
SECRETARIAT FIRE STATION, VIKASASOUDHA



Dr.B.R.AMBEDKAR VEEDI, VIDHANASOUDHA PRIMISESS, BENGALORE-560001

Gmail : dfossecretariat@gmail.com Tel : 080-22971603/22971602

No.24/CC/DFO/SVFS/BAN/2023

Dated: 21-09-2023.

ANNEXURE-B

"B1& B2 – Schools upto senior secondary level and other institutions"

NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings.

To,

M/s. Explorer's Academy

No.78/4,78/5, Halasahalli, Thippasandra

Gunjur Post, OFF Vartur Sarjapura Road

Bengaluru-560 087

Sir,

Sub: Issue of **Fire Safety Compliance Report** with respect to prevention, fire Fighting and Evacuation measures maintained at **"M/s. Explorer's Academy, No.78/4,78/5, Halasahalli, Thippasandra Gunjur Post, Off Vartur Sarjapura Road Bengaluru-560 087"**.

Ref: 1)) Inspection report No: 24/FSO/SVFS/BAN/2023. Date:21-09-2023.

2) Your request letter dated: 16-08-2023.

<<<>>>

With reference to the above cited subject, as per ref (1), a conditional Fire Safety Recommendation was issued to the premises **M/s. Explorer's Academy, No.78/4,78/5, Halasahalli, Thippasandra Gunjur Post, Off Vartur Sarjapura Road Bengaluru-560 087"**. With a condition to fulfill the recommendations and compliance the same within 3 months.

With reference cited (2) above, the management of **"M/s. Explorer's Academy, No.78/4,78/5, Halasahalli, Thippasandra Gunjur Post, Off Vartur Sarjapura Road Bengaluru-560 087"**. Had requested for the fire safety compliance report from our department. In this regard the above addressed educational building was inspected by the Fire Station Officer, Secretariat Fire Station. On **21-09-2023** for issue of fire safety compliance report.

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing the "Fire Safety Compliance Report to **"M/s. Explorer's Academy, No.78/4,78/5, Halasahalli, Thippasandra Gunjur Post, Off Vartur Sarjapura Road Bengaluru-560 087"**. Object to proper maintenance of fire fighting installations in the good working conditions and arrange for 40% of staffs/Employees training within 03 months from the date of issue of this report.

"This Fire Safety Compliance Report is valid for Only One Year from the date of issue and it is renewable".

Yours faithfully


DISTRICT FIRE OFFICER
KARNATAKA FIRE & EMERGENCY SERVICES
SECRETARIAT FIRE STATION
BANGALORE - 01



OFFICE OF THE DISTRICT FIRE OFFICER
KARNATAKA FIRE & EMERGENCY SERVICES
SECRETARIAT FIRE STATION, VIKASASOUDHA



Dr.B.R.AMBEDKAR VEEDI, VIDHANASOUDHA PRIMISESS, BENGALORE-560001

Gmail : dfossecretariat@gmail.com Tel : 080-22971603/22971602

No.24/CC/DFO/SVFS/BAN/2023

Dated: 21-09-2023.

ANNEXURE-B

"B1& B2 – Schools upto senior secondary level and other institutions"

NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings.

To,

M/s. Explorer's Academy

No.78/4,78/5, Halasahalli, Thippasandra

Gunjur Post, OFF Vartur Sarjapura Road

Bengaluru-560 087

Sir,

Sub: Issue of **Fire Safety Compliance Report** with respect to prevention, fire Fighting and Evacuation measures maintained at **"M/s. Explorer's Academy, No.78/4,78/5, Halasahalli, Thippasandra Gunjur Post, Off Vartur Sarjapura Road Bengaluru-560 087"**.

Ref: 1)) Inspection report No: 24/FSO/SVFS/BAN/2023. Date:21-09-2023.

2) Your request letter dated: 16-08-2023.

<<<>>>

With reference to the above cited subject, as per ref (1), a conditional Fire Safety Recommendation was issued to the premises **M/s. Explorer's Academy, No.78/4,78/5, Halasahalli, Thippasandra Gunjur Post, Off Vartur Sarjapura Road Bengaluru-560 087"**. With a condition to fulfill the recommendations and compliance the same within 3 months.

With reference cited (2) above, the management of **"M/s. Explorer's Academy, No.78/4,78/5, Halasahalli, Thippasandra Gunjur Post, Off Vartur Sarjapura Road Bengaluru-560 087"**. Had requested for the fire safety compliance report from our department. In this regard the above addressed educational building was inspected by the Fire Station Officer, Secretariat Fire Station. On **21-09-2023** for issue of fire safety compliance report.

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing the "Fire Safety Compliance Report to **"M/s. Explorer's Academy, No.78/4,78/5, Halasahalli, Thippasandra Gunjur Post, Off Vartur Sarjapura Road Bengaluru-560 087"**. Object to proper maintenance of fire fighting installations in the good working conditions and arrange for 40% of staffs/Employees training within 03 months from the date of issue of this report.

"This Fire Safety Compliance Report is valid for Only One Year from the date of issue and it is renewable".

Yours faithfully

Uma

Principal

Explorers Academy

Sy. No. 78/4,78/5, Halasahalli -
Thippasandra Village, Gunjur Post,
Sarjapura Hobli, Anekal Taluk,
Bangalore 560087.

Mamatha

Manager

Explorers Academy

Sy. No. 78/4,78/5, Halasahalli -
Thippasandra Village, Gunjur Post,
Sarjapura Hobli, Anekal Taluk,
Bangalore 560087.

S. S. S. S.
DISTRICT FIRE OFFICER

KARNATAKA FIRE & EMERGENCY SERVICES
SECRETARIAT FIRE STATION
BANGALORE - 01